

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman

FROM: Francis Bedetti, Asst. Fire inspector

SUBJECT: PB-07-201

First Columbia, 424 Ave. of America's
SBL: 3-1-50.32



DATE: February 13, 2007

Fire prevention Reference number: FPS-07-003

A review of the above referenced site plan has been conducted and is unacceptable for the following reasons:

- 1) 30' Fire lanes needed Front, Rear & one side
- 2) Re-adjust Drive lane (fire lane) configuration to eliminate sharp turns
- 3) F.D.C. to be located N.E. corner (north face)